

TABLE 2B
UNREINFORCED INTERNALLY BRACED ALLOWABLE HORIZONTAL WALL LENGTHS
(INTERMEDIATE PERIOD)

CMU Wall Thickness	Type S Mortar Cement Or Portland Cement/Lime	Type S Masonry Cement Or Air Entrained Portland Cement/Lime
8"	24'-0"	18'-8"
12"	32'-0"	24'-0"

Notes

- 1) Table values also applicable with Type M mortar.
- 2) Table valid for all masonry densities.
- 3) Table assumes ungrouted masonry, and is conservative for partially or fully grouted walls.
- 4) Table values applicable only with connected intersecting or return conditions at both ends of wall.

Produced for educational purposes only.

By: Todd Dailey, PE
Dailey Engineering, Inc.
www.daileyengineeringinc.com
todddailey@me.com

DISCLAIMER: The decision to utilize this information is not within the purview of Dailey Engineering, Inc. and persons making use of this information do so at their own risk. Dailey Engineering, Inc. makes no representation or warranties, expressed or implied, with respect to the accuracy or suitability of this information. Dailey Engineering, Inc. disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, which may result from the use of this information. This information is not to be interpreted as indicating compliance with, or waiver of, any provision of any applicable building code, ordinance, standard or law.

DISCLAIMER: This table is intended for use by those persons who are qualified and competent to evaluate the significant and limitations of its content. Dailey Engineering, Inc. disclaims any and all responsibility for the application of the stated material.